



DEPARTMENT OF FINANCE
PURCHASING & RISK MANAGEMENT

Questions and Answers

BTW BOILER REMOVAL & REPLACEMENT

Bids Remain Due – Friday, June 29, 2018, at 2:00 p.m.

1. Question: Does condensate pump vent have to be plumbed outside the building?

Answer: Yes. Code changes state the vent has to be piped outside the building. Please allow for approximately 50 foot of 2 inch PVC vent with overflow.