

Appendix F

Staunton Crossing Tank Inventory

Tank ID#	Type	Size	Fuel Type	Material	Status	Replaced With	DEQ ID#	James River Bar Code	Building ID
1	UST	10,000	Gas	Steel Step III	Complete	Tanks, piping and pumps brought up to code 1998	?		126
2	UST	5,000	Diesel	Steel Step III	Complete	Tanks, piping and pumps brought up to code 1998	?		126
3	AST	25,000	#6 Oil	Steel	Closed/Removed 1995	10,000 AST #2 oil	T-1	11638	114
4	AST	15,000	#6 Oil	Steel	Closed/Removed 1995	10,000 AST #2 oil	T-2	11639	114
7	UST	5,000	#2 Fuel Oil	Steel	Closed 1998	Not replaced.	N/A		124
8	UST	5,000	#2 Fuel Oil	Steel	Closed 1998	Not replaced.	N/A		123
10	AST	550	Diesel	Steel	Closed/Removed 1994	275 gallon steel AST DOUBLED WALL	T-10	11640	127
11	AST	550	Diesel	Steel	Closed 1998	275 gallon steel AST	T-3	11641	112
12	AST	550	Diesel	Fiberglass	Closed/Removed 1998	275 gallon steel AST	T-4	11642	115
13	AST	550	Diesel	Fiberglass	Closed/Removed 1998	275 gallon steel AST	T-5	11643	101
14	AST	550	Diesel	Fiberglass	Closed/Removed 1998	275 gallon steel AST	T-6	11644	102
15	AST	550	Diesel	Fiberglass	Closed/Removed 1998	275 gallon steel AST	T-7	11645	103
16	AST	550	Diesel	Fiberglass	Closed/Removed 1998	275 gallon steel AST	T-8	11646	107
17	UST	1,000	Premium Unleaded	Steel/Fiberglass	Closed 1998	Not replaced.	N/A		126
18	AST	250	Diesel	Steel/Day Tank	In use	275 gallon steel AST Part of generator	T-9	11647	118