



WESTERN STATE HOSPITAL HAZARDOUS MATERIALS SURVEY

LAB ANALYSIS BUILDING #121

SanAir Technologies Laboratory

Analysis Report

prepared for

El Group, Inc Roanoke Office

Report Date: 9/6/2013
Project Name: City Of Staunton
Project #: IHRO130196.00
SanAir ID#: 13020619



804.897.1177

www.sanair.com



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

EI Group, Inc Roanoke Office
15 Salem Ave SE
Suite 301
Roanoke, VA 24011

September 6, 2013

SanAir ID # 13020619
Project Name: City Of Staunton
Project Number: IHRO130196.00

Dear Melissa Hart,

We at SanAir would like to thank you for the work you recently submitted. The 69 sample(s) were received on Thursday, September 05, 2013 via FedEx. The final report(s) is enclosed for the following sample(s): 121-1, 121-2, 121-3, 121-4, 121-5, 121-6, 121-7, 121-8, 121-9, 121-10, 121-11, 121-12, 121-13, 121-14, 121-15, 121-16, 121-17, 121-18, 121-19, 121-20, 121-21, 121-22, 121-23, 121-24, 121-25, 121-26, 121-27, 121-28, 121-29, 121-30, 121-31, 121-32, 121-33, 121-34, 121-35, 121-36, 121-37, 121-38, 121-39, 121-40, 121-41, 121-42, 121-43, 121-44, 121-45, 121-46, 121-47, 121-48, 121-49, 121-50, 121-51, 121-52, 121-53, 121-54, 121-55, 121-56, 121-57, 121-58, 121-59, 121-60, 121-61, 121-62, 121-63, 121-64, 121-65, 121-66, 121-67, 121-68, 121-69.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

sample conditions:

69 sample(s) in Good condition



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-1 / 13020619-001 Cove Base	Black Non-Fibrous Homogeneous		100% Other	None Detected
121-1 / 13020619-001 Mastic	Various Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-2 / 13020619-002 Cove Base	Black Non-Fibrous Homogeneous		100% Other	None Detected
121-2 / 13020619-002 Mastic	Various Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-3 / 13020619-003	White Fibrous Homogeneous	60% Cellulose 30% Glass	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-4 / 13020619-004	White Fibrous Homogeneous	60% Cellulose 30% Glass	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-5 / 13020619-005	Black Non-Fibrous Homogeneous		90% Other	10% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-6 / 13020619-006	Black Non-Fibrous Homogeneous		90% Other	10% Chrysotile

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 1 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-7 / 13020619-007	Beige Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-8 / 13020619-008	Beige Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-9 / 13020619-009	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-10 / 13020619-010	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-11 / 13020619-011 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-11 / 13020619-011 Mastic	Black Non-Fibrous Homogeneous		97% Other	3% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-12 / 13020619-012 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-12 / 13020619-012 Mastic	Various Non-Fibrous Homogeneous		97% Other	3% Chrysotile

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 2 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-13 / 13020619-013	Various Non-Fibrous Homogeneous	7% Glass	93% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-14 / 13020619-014	Various Non-Fibrous Homogeneous	7% Glass	93% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-15 / 13020619-015 Wrap	Various Fibrous Homogeneous	55% Cellulose 4% Glass	41% Other	None Detected
121-15 / 13020619-015 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-16 / 13020619-016 Wrap	Various Fibrous Homogeneous	55% Cellulose 4% Glass	41% Other	None Detected
121-16 / 13020619-016 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-17 / 13020619-017	Various Non-Fibrous Homogeneous	10% Cellulose 20% Glass	70% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-18 / 13020619-018	Various Non-Fibrous Homogeneous	10% Cellulose 20% Glass	70% Other	None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 3 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-19 / 13020619-019 Ceramic Tile	White Non-Fibrous Homogeneous		100% Other	None Detected
121-19 / 13020619-019 Grout	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-20 / 13020619-020 Ceramic Tile	White Non-Fibrous Homogeneous		100% Other	None Detected
121-20 / 13020619-020 Grout	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-21 / 13020619-021 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-21 / 13020619-021 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-22 / 13020619-022 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-22 / 13020619-022 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-23 / 13020619-023 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-23 / 13020619-023 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 4 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-24 / 13020619-024 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-24 / 13020619-024 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-25 / 13020619-025 Floor Tile	Peach Non-Fibrous Homogeneous		100% Other	None Detected
121-25 / 13020619-025 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-26 / 13020619-026 Floor Tile	Peach Non-Fibrous Homogeneous		100% Other	None Detected
121-26 / 13020619-026 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-27 / 13020619-027 Drywall	Off-White Non-Fibrous Homogeneous	< 1% Cellulose < 1% Glass	100% Other	None Detected
121-27 / 13020619-027 Texture	White Non-Fibrous Homogeneous		98% Other	2% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-28 / 13020619-028 Drywall	Off-White Non-Fibrous Homogeneous	< 1% Cellulose < 1% Glass	100% Other	None Detected
121-28 / 13020619-028 Texture	White Non-Fibrous Homogeneous		98% Other	2% Chrysotile

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 5 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-29 / 13020619-029	White Fibrous Homogeneous	55% Cellulose 35% Glass	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-30 / 13020619-030	White Fibrous Homogeneous	55% Cellulose 35% Glass	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-31 / 13020619-031 Floor Tile	Off-White Non-Fibrous Homogeneous		100% Other	None Detected
121-31 / 13020619-031 Mastic	Various Non-Fibrous Homogeneous		97% Other	3% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-32 / 13020619-032 Floor Tile	Off-White Non-Fibrous Homogeneous		100% Other	None Detected
121-32 / 13020619-032 Mastic	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-33 / 13020619-033	White Fibrous Homogeneous	20% Cellulose 60% Glass	20% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-34 / 13020619-034	White Fibrous Homogeneous	20% Cellulose 60% Glass	20% Other	None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 6 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-35 / 13020619-035	Brown Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-36 / 13020619-036	Brown Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-37 / 13020619-037	Pink Fibrous Homogeneous	65% Glass 20% Cellulose	15% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-38 / 13020619-038	Pink Fibrous Homogeneous	65% Glass 20% Cellulose	15% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-39 / 13020619-039	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-40 / 13020619-040 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-40 / 13020619-040 Mastic	Various Non-Fibrous Homogeneous	3% Cellulose	95% Other	2% Chrysotile

Certification

Signature: *Susan Childress*
Date: 9/6/2013

Reviewed: *[Signature]*
Date: 9/6/2013

Page 7 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-41 / 13020619-041 Floor Tile	Beige Non-Fibrous Homogeneous		100% Other	None Detected
121-41 / 13020619-041 Mastic	Various Non-Fibrous Homogeneous	2% Cellulose	98% Other	< 1% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-42 / 13020619-042	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-43 / 13020619-043	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-44 / 13020619-044	Various Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-45 / 13020619-045	Various Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-46 / 13020619-046	Black Non-Fibrous Homogeneous		95% Other	5% Chrysotile

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 8 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-47 / 13020619-047	Black Non-Fibrous Homogeneous		95% Other		5% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-48 / 13020619-048	Beige Non-Fibrous Homogeneous	6% Cellulose 4% Glass	90% Other		None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-49 / 13020619-049	Grey Fibrous Homogeneous		20% Other		80% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-50 / 13020619-050	Various Fibrous Homogeneous	80% Glass	20% Other		None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-51 / 13020619-051	Various Fibrous Homogeneous	80% Glass	20% Other		None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-52 / 13020619-052	Various Non-Fibrous Heterogeneous		100% Other		None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-53 / 13020619-053	Various Non-Fibrous Homogeneous		100% Other		None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 9 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-54 / 13020619-054	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-55 / 13020619-055	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-56 / 13020619-056	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-57 / 13020619-057	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-58 / 13020619-058	Tan Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-59 / 13020619-059	Tan Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-60 / 13020619-060	Beige Non-Fibrous Homogeneous	20% Glass	75% Other	5% Chrysotile

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 10 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-61 / 13020619-061	Beige Non-Fibrous Homogeneous	20% Glass 2% Cellulose	73% Other	5% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-62 / 13020619-062 Plaster	Grey Non-Fibrous Homogeneous		100% Other	None Detected
121-62 / 13020619-062 Skim Coat	White Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-63 / 13020619-063 Plaster	Grey Non-Fibrous Homogeneous		100% Other	None Detected
121-63 / 13020619-063 Skim Coat	White Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-64 / 13020619-064	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-65 / 13020619-065	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-66 / 13020619-066	Grey Non-Fibrous Homogeneous		100% Other	None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 11 of 12



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13020619

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: City Of Staunton

Collected Date: 9/3/2013
Received Date: 9/5/2013 10:15:00 AM
Report Date: 9/6/2013 10:46:49 AM
Analyst: Childress, Susan

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-67 / 13020619-067	Grey Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-68 / 13020619-068	Beige Non-Fibrous Homogeneous		100% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components	Asbestos Fibers
			% Non-Fibrous	
121-69 / 13020619-069	Beige Non-Fibrous Homogeneous		100% Other	None Detected

Certification

Signature: 
Date: 9/6/2013

Reviewed: 
Date: 9/6/2013

Page 12 of 12

Disclaimer

The final report cannot be reproduced, except in full, without written authorization from SanAir. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government.

For NY state samples, method EPA 600/M4-82-020 is performed.

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

NY ELAP lab ID 11983

AMERISCI

AMERISOL
Job No.:

AmeriSci *Richmond*
13635 Genito Road
Midlothian, VA 23112
Phone: (804) 763-1200
Fax: (804) 763-1800
TOLL FREE: (800) 476-5227
www.amerisci.com

SEP 05 2013 10:15 AM

SanAir Technologies Laboratory

Analysis Report

prepared for

El Group, Inc Roanoke Office

Report Date: 9/11/2013
Project Name: Western State
Hospital
Project #: IHRO130196.00
SanAir ID#: 13021164



804.897.1177

www.sanair.com



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

EI Group, Inc Roanoke Office
15 Salem Ave SE
Suite 301
Roanoke, VA 24011

September 11, 2013

SanAir ID # 13021164
Project Name: Western State Hospital
Project Number: IHRO130196.00

Dear Melissa Hart,

We at SanAir would like to thank you for the work you recently submitted. The 4 sample(s) were received on Tuesday, September 10, 2013 via FedEx. The final report(s) is enclosed for the following sample(s): 121-70, 121-71, 121-72, 121-73.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:
- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

sample conditions:
4 sample(s) in Good condition



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13021164

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: Western State Hospital

Collected Date: 9/9/2013
Received Date: 9/10/2013 9:30:00 AM
Report Date: 9/11/2013 11:15:27 AM
Analyst: Tallert, Jonathan G.

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-70 / 13021164-001 Tar	Black Non-Fibrous Homogeneous	45% Cellulose	55% Other	None Detected
121-70 / 13021164-001 Insulation	Tan Fibrous Homogeneous	90% Cellulose	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-71 / 13021164-002 Insulation	Grey Fibrous Homogeneous	60% Min. Wool 20% Cellulose	20% Other	None Detected
121-71 / 13021164-002 Insulation	Tan Fibrous Homogeneous	90% Cellulose	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-72 / 13021164-003 Tar	Black Non-Fibrous Homogeneous	45% Cellulose	55% Other	None Detected
121-72 / 13021164-003 Insulation	Tan Fibrous Homogeneous	90% Cellulose	10% Other	None Detected

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-73 / 13021164-004 Tar	Black Non-Fibrous Homogeneous	45% Cellulose	55% Other	None Detected
121-73 / 13021164-004 Insulation	Grey Fibrous Homogeneous	60% Min. Wool 20% Cellulose	20% Other	None Detected

Certification

Signature: 
Date: 9/11/2013

Reviewed: 
Date: 9/11/2013

Page 1 of 1

Disclaimer

The final report cannot be reproduced, except in full, without written authorization from SanAir. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government.

For NY state samples, method EPA 600/M4-82-020 is performed.

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

NY ELAP lab ID 11983

SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B - Powhatan, VA 23139
804-897-1177 / 888-895-1177 / Fax 804-897-0070
www.sanair.com

Asbestos Chain of Custody

SanAir ID Number

13021164

Company: <u>The E1 Group - Staunton</u>		Project #: <u>1480130196 00</u>	Collect by:
Address:		Project Name: <u>Duke's State Hospital</u>	Phone #:
City, St., Zip:		Date Collected: <u>9-9-13</u>	Fax #:
State of Collection: <u>VA</u>	Account#:	P.O. Number:	Email:

Bulk		Air		Soil/Vermiculite	
ABB	PLM EPA 600/R-93/116 ☒	ABA	PCM NIOSH 7400 ☐	ABSE	PLM EPA 600/R-93/116 (Qual.) ☐
	Positive Stop ☐	ABA-2	OSHA w/ TWA* ☐	ABSP	PLM CARB 435 (LOD <1%) ☐
ABEPA	PLM EPA 400 Point Count ☐	ABTEM	TEM AHERA ☐	ABSP1	PLM CARB 435 (LOD 0.25%) ☐
ABB1K	PLM EPA 1000 Point Count ☐	ABATN	TEM NIOSH 7402 ☐	ABSP2	PLM CARB 435 (LOD 0.1%) ☐
ABBEN	PLM EPA NOB ☐	ABT2	TEM Level II ☐		
ABBCH	TEM Chatfield ☐				
ABBTM	TEM EPA NOB ☐				
Water		New York ELAP		Dust	
ABHE	EPA 100.2 ☐	PLM NY	PLM 600/M4/B2/020 ☐	ABWA	TEM Wipe ASTM D-6480 ☐
		ABEPA2	NY ELAP 198.1 ☐	ABDMV	TEM Microvac ASTM D-5755 ☐
		ABENY	NY ELAP 198.6 PLM NOB ☐	Matrix	Other ☐
		ABBNY	NY ELAP 198.4 TEM NOB ☐		

Turn Around Times	3 HR (4 HR TEM) ☐	6 HR (8HR TEM) ☐	12 HR ☐	24 HR ☒
	2 Days ☐	3 Days ☐	4 Days ☐	5 Days ☐

Special Instructions	<u>Email results to mhart@ei1.com</u>
----------------------	---------------------------------------

Sample #	Sample Identification/Location	Volume or Area	Sample Type	Flow Rate*	Time* Start - Stop
121-70					
↓					
121-73					

Relinquished by	Date	Time	Received by	Date	Time
<u>[Signature]</u>	9-9-13	15:40	<u>[Signature]</u>	SEP 10 2013	9:30 AM

Unless scheduled, the turn around time for all samples received after 3 pm EST Friday will begin at 8 am Monday morning. Weekend or Holiday work must be scheduled ahead of time and is charged for rush turn around time. Work with standard turn around time sent Priority Overnight and Billed To Recipient will be charged a \$10 shipping fee.

Page ___ of ___

SanAir Technologies Laboratory

Analysis Report

prepared for

El Group, Inc Roanoke Office

Report Date: 9/19/2013
Project Name: Western State Hosp.
Project #: IHR0130196
SanAir ID#: 13022021



NVLAP LAB CODE 200870-0



Certification # 652931



License # LAB0166



804.897.1177

www.sanair.com



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

EI Group, Inc Roanoke Office
15 Salem Ave SE
Suite 301
Roanoke, VA 24011

September 19, 2013

SanAir ID # 13022021
Project Name: Western State Hosp.
Project Number: IHR0130196

Dear Stephen Clark,

We at SanAir would like to thank you for the work you recently submitted. The 1 sample(s) were received on Wednesday, September 18, 2013 via FedEx. The final report(s) is enclosed for the following sample(s): 121-74.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:
- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

sample conditions:
1 sample(s) in Good condition



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13022021

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHR0130196
P.O. Number: Bldg 121
Project Name: Western State Hosp.

Collected Date: 9/17/2013
Received Date: 9/18/2013 9:50:00 AM
Report Date: 9/19/2013 8:33:34 AM
Analyst: Tallert, Jonathan G.

Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic Appearance	Components		Asbestos Fibers
		% Fibrous	% Non-Fibrous	
121-74 / 13022021-001	Grey Non-Fibrous Homogeneous		93% Other	7% Chrysotile

Certification

Signature: 
Date: 9/18/2013

Reviewed: 
Date: 9/19/2013

Page 1 of 1

Disclaimer

The final report cannot be reproduced, except in full, without written authorization from SanAir. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government.

For NY state samples, method EPA 600/M4-82-020 is performed.

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

NY ELAP lab ID 11983

1551 Oakbridge Drive, Suite B - Powhatan, VA 23139
804-897-1177 / 888-895-1177 / Fax 804-897-0070
www.sanair.com

SanAir ID Number

13022021

Company: <u>EJ Group, Inc.</u>		Project #: <u>JHR0130196</u>	Collect by: <u>Stephen Clark</u>
Address: <u>206 Walnut Hills Rd</u>		Project Name: <u>Western State Hosp.</u>	Phone #:
City, St., Zip: <u>Staunton, VA</u>		Date Collected: <u>9/17/2013</u>	Fax #:
State of Collection: <u>VA</u> Account#:		P.O. Number: <u>Bldg 121</u>	Email:

Bulk			Air			Soil/Vermiculite		
ABB	PLM EPA 600/R-93/116	☒	ABA	PCM NIOSH 7400	☐	ABSE	PLM EPA 600/R-93/116 (Qual.)	☐
	Positive Stop ☐		ABA-2	OSHA w/ TWA*	☐	ABSP	PLM CARB 435 (LOD <1%)	☐
ABEPA	PLM EPA 400 Point Count	☐	ABTEM	TEM AHERA	☐	ABSP1	PLM CARB 435 (LOD 0.25%)	☐
ABB1K	PLM EPA 1000 Point Count	☐	ABATN	TEM NIOSH 7402	☐	ABSP2	PLM CARB 435 (LOD 0.1%)	☐
ABBN	PLM EPA NOB	☐	ABT2	TEM Level II	☐			
ABBC	TEM Chatfield	☐						
ABBTM	TEM EPA NOB	☐						
Water			New York ELAP			Dust		
			PLM NY	PLM 600/M4/82/020	☐	ABWA	TEM Wipe ASTM D-6480	☐
			ABEPA2	NY ELAP 198.1	☐	ABDMV	TEM Microvac ASTM D-5755	☐
			ABENY	NY ELAP 198.6 PLM NOB	☐	Matrix	Other	
ABHE	EPA 100.2	☐	ABBNY	NY ELAP 198.4 TEM NOB	☐			

Turn Around Times	3 HR (4 HR TEM) ☐	6 HR (8HR TEM) ☐	12 HR ☐	24 HR ☒
	2 Days ☐	3 Days ☐	4 Days ☐	5 Days ☐

Special Instructions

[illegible]

Relinquished by	Date	Time	Received by	Date	Time
<i>[Signature]</i>	9/17/2013	17:00	<i>[Signature]</i>	SEP 18 2013	9:50am

Unless scheduled, the turn around time for all samples received after 3 pm EST Friday will begin at 8 am Monday morning. Weekend or Holiday work must be scheduled ahead of time and is charged for rush turn around time. Work with standard turn around time sent Priority Overnight and Billed To Recipient will be charged a \$10 shipping fee.

Page 1 of 1

SanAir Technologies Laboratory

Analysis Report

prepared for

El Group, Inc Roanoke Office

Report Date: 9/20/2013
Project Name: Western State Hosp.
Bldg. 121
Project #: IHRO130196.00
SanAir ID#: 13022143



804.897.1177

www.sanair.com



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

EI Group, Inc Roanoke Office
15 Salem Ave SE
Suite 301
Roanoke, VA 24011

September 20, 2013

SanAir ID # 13022143
Project Name: Western State Hosp. Bldg. 121
Project Number: IHRO130196.00

Dear Melissa Hart,

We at SanAir would like to thank you for the work you recently submitted. The 4 sample(s) were received on Thursday, September 19, 2013 via Fax or Email request. The final report(s) is enclosed for the following sample(s): 121-27, 121-28, 121-40, 121-41.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:
- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

sample conditions:
4 sample(s) in Good condition



SanAir Technologies Laboratory, Inc.

1551 Oakbridge Drive, Suite B, Powhatan, VA 23139
804.897.1177 Toll Free: 888.895.1177 Fax: 804.897.0070
Web: <http://www.sanair.com> E-mail: iaq@sanair.com

SanAir ID Number

13022143

FINAL REPORT

Name: El Group, Inc Roanoke Office
Address: 15 Salem Ave SE
Suite 301
Roanoke, VA 24011

Project Number: IHRO130196.00
P.O. Number:
Project Name: Western State Hosp. Bldg. 121
Collected Date: 9/3/2013
Received Date: 9/19/2013 8:00:00 AM
Report Date: 9/20/2013 9:31:47 AM
Analyst: Childress, Susan

Asbestos Bulk EPA PLM 400 Point Count

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-27 / 13022143-001	White Non-Fibrous Homogeneous		100% Other		< 0.25% Chrysotile

SanAir ID / Description	Stereoscopic Appearance	% Fibrous	Components		Asbestos Fibers
			% Non-Fibrous		
121-28 / 13022143-002	White Non-Fibrous Homogeneous		100% Other		< 0.25% Chrysotile

Certification

Signature: 
Date: 9/20/2013

Reviewed: 
Date: 9/20/2013

Page 1 of 1

Disclaimer

The final report cannot be reproduced, except in full, without written authorization from SanAir. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. This report may not be used by the client to claim product endorsement by NVLAP, AIHA or any other agency of the U.S. government; *and may not be certified by every local, state and federal regulatory agencies.*

Suppose that $\mathcal{C}$ is a class of structures

AMERISCI RICHMOND
Job No.:

13022143
15020614

AmeriSci Richmond
13635 Genito Road
Midlothian, VA 23112
Phone: (804) 763-1200
Fax: (804) 763-1800
TOLL FREE: (800) 476-5227
www.ameriscisc.com

Environmental Investigations, P.A.		200 Walnut Hills Road Staunton, VA 24401		P.O.#: SPECIAL INSTRUCTIONS:						
PROJECT INFORMATION		ANALYSIS TYPE		TURNAROUND TIME (X)				AIR FILTER INFORMATION:		
				6-8 Hr	12 Hr	24 Hr	48 Hr	72 Hr	5 DAY	OTHER
JOB NAME: City of Staunton		TEM/AHERA								
JOB NO.: 1H80130196.00		TEM/LEVEL II								
JOB MANAGER: Melissa Hart		TEM/7402								
JOB DESCRIPTION: Western State Hsp Bldg. 121		TEM/BULK								
RESULTS TO: MELISSA HART		TEM/DUST								
INVOICE TO: ENVIRONMENTAL		TEM/WATER								
RETURN SAMPLES: Yes ☒ No ☒		PLM								
PHONE: (540) 337-3740		PCM								
FAX: (540) 337-9075		OTHER:								
EMAIL RESULTS: (Y) N MHART@eif.com		SITE FAX:								
WRITTEN REPORT TO:		PAGER/CELL: 540-448-5802								
COMMENTS:		DATE/TIME:								
RECEIVED BY:		DATE/TIME:								
RECEIVED IN LAB BY:		DATE/TIME:								

SEP 05 2013 10:15 AM

SEP 19 2013 8:00 AM

Chelsea A. Rawes

From: Sandra C. Sobrino
Sent: Thursday, September 19, 2013 8:28 AM
To: Chelsea A. Rawes; Kaitlyn E. Jones
Subject: FW: SanAir Site Access Information

Follow Up Flag: Follow up

Flag Status: Completed

ABEPA 24 tat on job Ihro130196.00
Samples to be Point Counted: 34 total
102-47 & 48, 1,2, 3 & 4
113-12 & 13,14,15, 16, 17,, 21 22, 23
121- 27, 28, 40 41
124 -17, 18
126 -10, 25, 26
112 - 46
101-39, 40
127-31,35,36,16,17,
123-3,4 composite sample (drywall and joint compound)

From: Melissa Hart [mailto:mhart@ei1.com]
Sent: Thursday, September 19, 2013 5:53 AM
To: Sandra C. Sobrino
Subject: Re: SanAir Site Access Information

Ihro130196.00 yes 24 tat Thanks.

On Sep 18, 2013, at 5:54 PM, "Sandra C. Sobrino" <ssobrino@sanair.com> wrote:

Melissa,

Which job is this for ? and please confirm 24 tat as well.

Sandra Sobrino
ssobrino@sanair.com
Director of asbestos and material science division
SanAir Technologies Laboratory, Inc.
773-454-0773

----- Original message -----

Subject: Fwd: SanAir Site Access Information
From: Dave Burrington <dburrington@sanair.com>
To: "Sandra C. Sobrino" <ssobrino@sanair.com>, "Jonathan G. Tallert" <jtallert@sanair.com>
CC:

Please see below.

9/19/2013

CP

SEP 19 2013 8:00 AM

Dave Burrington
SanAir Technologies Laboratory, Inc.

Sent from my Verizon Wireless 4G LTE DROID

----- Original Message -----

Subject: RE: SanAir Site Access Information
From: Melissa Hart <mhart@ei1.com>
To: Dave Burrington <dburrington@sanair.com>
CC:

Dave,

Samples to be Point Counted: 34 total

102-47 & 48, 1,2, 3 & 4
113-12 & 13,14,15, 16, 17,, 21 22, 23
121- 27, 28, 40 41
124 -17, 18
126 -10, 25, 26
112 - 46
101-39, 40
127-31,35,36,16,17,
123-3,4 composite sample (drywall and joint compound)

From: Dave Burrington [<mailto:dburrington@sanair.com>]
Sent: Wednesday, September 18, 2013 4:44 PM
To: Melissa Hart
Subject: SanAir Site Access Information

Melissa,

You can now login into your SanAir account via <https://www.sanair.net/reports/> using your designated username and password. Our online reporting database will allow for you to do the following:

- 1). View and print out your lab test results in full color format, signed by the analysts
- 2). Print customized chain of custody forms that include your company information already populated in the fields
- 3). Store and archive your reports for future reference
- 4). View and print your invoices as your jobs are reported (Authorization Required - contact customer service for access to online invoices)

*** New Website Feature ***

9/19/2013

 SEP 19 2013 8:00 AM

In 3 easy steps, you can now prepare and print FedEx labels to ship your samples to the lab directly from our website. Your company information and SanAir Account number will ensure prompt, next business day shipping.

Your SanAir Account#: 1009

User ID: mhart

Password: melissa1500

If you have any questions, please call 888-895-1177.

Customer Services
SanAir Technologies Laboratory
1551 Oakbridge Drive Suite B
Powhatan VA 23139
Phone: 804-897-1177
Fax: 804-897-0070

9/19/2013

SEP 19 2013 8:00 AM