

SYSTEM RECORD OF INSPECTION AND TESTING

This form is to be completed by the system inspection and testing contractor at the time of a system test.

It shall be permitted to modify this form as needed to provide a more complete and/or clear record.

Insert N/A in all unused lines.

Attach additional sheets, data, or calculations as necessary to provide a complete record.

Inspection/Test Start Date/Time: 04/08/2019 09:00

Inspection/Test Completion Date/Time: 04/08/2019 11:30

Supplemental Form(s) Attached: No (yes/no)

1. PROPERTY INFORMATION

Name of property: City of Staunton - Public Library

Address: 1 Churchville Ave., Staunton, VA. 24401

Description of property: Library

Name of property representative: Tim Powell

Address: 1911 Craigmont Rd., Staunton, VA. 24401

Phone: 540-332-3892

Fax: _____

E-mail: powelltc@ci.staunton.va.us

2. TESTING AND MONITORING INFORMATION

Testing organization: Greer's Supply Co., Inc.

Address: 2401-A Plantation Rd. NE, Roanoke, VA. 24012

Phone: 540-265-0555

Fax: 540-265-0554

E-mail: craig@greersupply.com

Monitoring organization: Vector Security

Address: 2805 N. Parham Rd., Suite 500, Richmond, VA. 23294

Phone: 800-666-4642

Fax: _____

E-mail: ashawthorne@vectorsecurity.com

Account number: 691-0870

Phone line 1: _____

Phone line 2: _____

Means of transmission: DACT

Entity to which alarms are retransmitted: City of Staunton E911

Phone: 540-885-6877

3. DOCUMENTATION

On-site location of the required record documents and site-specific software: none

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

Manufacturer: FireLite

Model number: MS4824

4.2 Software and Firmware

Firmware revision number: unknown

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: 120

Amps: 4

Location: 1FL Circulation Desk

Overcurrent protection type: Breaker

Amps: 20

Disconnecting means location: Panel B #24

SYSTEM RECORD OF INSPECTION AND TESTING *(continued)*

4. DESCRIPTION OF SYSTEM OR SERVICE *(continued)*

4.3.2 Secondary Power

Type: Battery Location: in Panel

Battery type (if applicable): Sealed Lead-Acid

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 5

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization	Contact: <u>Vector Security</u>	Time: <u>09:25</u>
Building management	Contact: <u>Roger Gay</u>	Time: <u>09:25</u>
Building occupants	Contact: <u>Verbal</u>	Time: <u>09:25</u>
Authority having jurisdiction	Contact: <u>N/A</u>	Time: _____
Other, if required	Contact: <u>N/A</u>	Time: _____

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	☒	☒	
Lamps/LEDs/LCDs	☒	☒	
Fuses	☒	☒	
Trouble signals	☒	☒	
Disconnect switches	☐	☐	N/A
Ground-fault monitoring	☒	☐	
Supervision	☐	☐	N/A
Local annunciator	☐	☐	N/A
Remote annunciators	☐	☐	N/A
Remote power panels	☐	☐	N/A
	☐	☐	

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Comments
Battery condition	☒	☒	Installed 1/12/2018 tested better than rated capacity
Load voltage	☒	☒	
Discharge test	☒	☒	
Charger test	☒	☒	
Remote panel batteries	☐	☐	N/A
	☐	☐	

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.3 Alarm and Supervisory Alarm Initiating Device

Device Type	Address	Location	Test Results
Pull	1	Gnd FL@Right Stair	Pass
Pull	2	Gnd FL@Left Stair	Pass
Pull	2	Gnd FL@Program Room	Pass
Smoke w/Confirm	2	Gnd FL Mechanical (Boiler) Room	Pass
Smoke w/Confirm	2	Gnd FL Storage@Sprinkler Room	Pass
Smoke w/Confirm	2	Gnd FL Sprinkler Room	Pass
Smoke w/Confirm	2	Gnd FL Mechanical (HVAC) Room	Pass
Smoke	3	Gnd FL Elevator Eqpt Rm	Pass
Smoke	3	Gnd FI Elevator Lobby	Pass
Duct Smoke	4	Gnd FL Mechanical (HVAC) Room	Pass
Pull	11	1FL Circulation Desk	Pass
Pull	11	1FL@Right Stair	Pass
Pull	11	E in Right Stair@ Exit	Pass
Pull	11	1FL@Left Stair	Pass
Pull	11	1FL in Left Stair@Exit	Pass
Smoke w/Confirm	12	E Mailroom	Pass
Smoke w/Confirm	12	1FL Circulation Storage	Pass
Smoke	13	E Elevator Lobby	Pass
Smoke	13	1FL Elevator Lobby	Pass
Pull	14	2FL@Left Stair	Pass
Pull	14	2FL@Right Stair	Pass
Smoke	15	2FL Director Supply Closet	Pass
Smoke	15	2FL File Room	Pass
Smoke	15	2FL Lounge	Pass
Smoke	15	2FL Tech Svcs Storage	Pass
Smoke	15	2FL Sprinkler Room	Pass
Smoke	15	2FL Meeting Room Storage	Pass
Smoke	16	2FL Elevator Lobby	Alarm - No Recall
Smoke	16	Elevator Top-of-Shaft	Not Tested
Duct Smoke	17	2FL Mechanical Room	Pass
Monitor	18	Dry Riser Tamper/Waterflow	Tested by Others
Monitor	19	No Connection	Not Tested
Monitor	9	Gnd FL Sprinkler Waterflow	Tested by Others
Monitor	10	Gnd FL Sprinkler Valve Tamper	Tested by Others

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.4 Notification Appliances

[illegible]

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.5 Interface Equipment

Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface

Interface Type	Location/Identifier	Test Results

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	☒	☐	9:25	
Alarm restoration	☐	☒	N/A	
Trouble signal	☒	☐	10:49	
Trouble restoration	☒	☐	10:51	
Supervisory signal	☐	☒	N/A	
Supervisory restoration	☐	☒	N/A	

7. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization	Contact: <u>Vector Security</u>	Time: <u>11:20</u>
Building management	Contact: <u>Roger Gay</u>	Time: <u>11:20</u>
Building occupants	Contact: <u>Verbal</u>	Time: <u>11:30</u>
Authority having jurisdiction	Contact: <u>N/A</u>	Time: <u> </u>
Other, if required	Contact: <u>N/A</u>	Time: <u> </u>

8. SYSTEM RESTORED TO NORMAL OPERATION

Date: 04/08/2019 Time: 11:30

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2013 edition, Chapter 14.

Signed: Craig Dickerson Printed name: Craig Dickerson Date: 04/08/2019
 Organization: Greer's Supply Co., Inc. Title: Fire & Security Technician Phone: 540-312-4403
 Qualifications (refer to 10.5.3): VA DCJS 11-4689, 99-168356

10. DEFECTS OR MALFUNCTIONS NOT CORRECTED AT CONCLUSION OF SYSTEM INSPECTION, TESTING, OR MAINTENANCE

Elevator did not recall on 2FL Lobby Smoke Alarm

10.1 Acceptance by Owner or Owner's Representative:

The undersigned accepted the test report for the system as specified herein:

Signed: Roger Gay Printed name: Roger Gay Date: 04/08/2019
 Organization: City of Staunton Public Works Title: Technician Phone: 540-490-1123