

DEPARTMENT OF FINANCE

To: All Potential Offerors

Date: March 10, 2020

Subject: **Addendum #4** to **IFB C00120** dated **February 11, 2020**

Title: **Tank Painting – Shutterlee Mill Tank**

Addendum #4 is issued to address the following changes to **Section 8.6.2**:

8.6.2 Exterior Tank Coating System: (AWWA D102-17, OCS-5)

- a. Surface Preparation: Power wash the entire exterior surface using 4,000 PSI with a rotating turbo nozzle to remove all loose paint, rust, chalk, mildew, dirt, scale, and all other foreign matter. Great Lakes Laboratories Extra Muscle Pre-paint Cleaner shall be used prior to power washing to help remove all the existing chalk from the tank prior to painting. SSPC-SP3 Power Tool Cleaning to all areas with rust and corrosion. Pole sand the entire surface to feather the edges of the tightly adhered existing paint. Spot prime all cleaned areas with Sherwin Williams Epoxy Mastic Aluminum II @ 4.0 – 6.0 dry mils.
- b. First Coat: Sherwin Williams Macropoxy 920 PrePrime Epoxy @ 1.5 – 2.0 dry mils.
- c. Second Coat: Sherwin Williams Acrolon 218 HS Polyurethane @ 3.0 – 6.0 dry mils.
- d. Third Coat: Sherwin Williams Fluorokem HS Urethane @ 2.0 – 3.0 dry mils.

Inquiries Concerning the Bid

Any questions or comments concerning this Invitation to Bid should be directed in writing to:

Nathan Simmons
Utility Technical Service Supervisor
P.O. Box 58
Staunton, Virginia 24402-0058
ssimmonsnl@ci.staunton.va.us

Note: A signed acknowledgement of this addendum must be received by this office prior to the due date and time, or must be attached to your bid. Signature on this addendum does not constitute signature on the original bid document. The original bid document must also be signed per bid instructions.

Respectfully,



Chad Horvat
Finance Business Manager

Company Name: _____

Signature: _____

Type/Print Name: _____

Title: _____

Date: _____