

DEPARTMENT OF FINANCE

To: **Potential Offerors**
Date: **June 10, 2020**
Subject: **Addendum #3 to IFB E00220 dated May 19, 2020**
Title: **Central Avenue Streetscape Improvements**

Addendum #3 is issued to address the following Question and Answer and to update the ZOOM Webinar Bid Opening login/connection instructions.

Additional Questions & Answers

- Q1) Drawing E0 In-Grade pull box detail shows a polymer concrete box with a HS-20 cover. Polymer box and cover only offer Tier 22 as the highest rating, HS-20 is a precast concrete box with a steel cover. Please advise.
A1) Tier 22 polymer box is acceptable.
- Q2) What materials should the crosswalks made of?
A2) Crosswalks shall be constructed with concrete pavers per City technical specifications, Section 110, with total section depth as shown on plans.
- Q3) Is it possible to include an asphalt escalation clause?
A3) The city does not wish to include an asphalt escalation clause.

ZOOM Webinar Bid Opening

When: June 25, 2020 2:00 PM EST (US and Canada)

Topic: Central Avenue Streetscape – Bid Opening

Please click the link below to join the webinar:

<https://us02web.zoom.us/j/83608479392?pwd=T2lzKzFBNFdiQlhocTdvR0pFUk9uUT09>

Password: 234463

Or Telephone:

Dial (for higher quality, dial a number based on your current location):

US: +1 312 626 6799 or +1 929 205 6099 or +1 301 715 8592 or +1 346 248 7799 or
+1 669 900 6833 or +1 253 215 8782

Webinar ID: 836 0847 9392

Password: 234463

DEPARTMENT OF FINANCE

Note: A signed acknowledgment of this addendum must be received at the location indicated on the solicitation either prior to the solicitation due date and hour or attached to your proposal. Signature on this addendum does not substitute for your signature on the original bid/proposal document. The original proposal document must be signed.

Respectfully,



Chad Horvat, Finance Business Manager

Company Name of Offeror

Signature & Title

Date